

**From:** Moss, Mark  
**Sent:** 18 June 2018 16:31  
**To:** Chisnall, Emma <[Emma.Chisnall@havant.gov.uk](mailto:Emma.Chisnall@havant.gov.uk)>  
**Subject:** Change of use of no.260 and no.262 London Road - app/18/00059

Good day Emma

I've had a look at the more detailed report Ventilation & Extraction statement, submitted in relation to the extraction systems to be employed.

I note that reference is made to a noise level of 67 dB & that silencers that can reduce sound levels by 10 dB can be fitted if required. As it appears no noise / acoustic assessment has been carried out, I have no idea as to the existing background noise levels in relation to the advised noise output levels of the proposed systems to be employed, and whether or not the silencers that may or may not be used will suffice or whether they will actually be required.

I would therefore suggest that the applicant provide an acoustic assessment in relation to this application in order that a clearer understanding of the potential noise levels, and whether any mitigation measures are required. This is in order to ensure that there is no adverse impact on the nearest residential receptors.

I would also ask that it be clarified what the proposed cuisine will be, if known, and if not to what level the odour and grease control currently proposed, will suffice going forward.

Regards

Mark Moss  
Regulatory Officer  
Environmental Health  
Havant Borough Council, Public Service Plaza, Civic Centre Road, Havant PO9 2AX  
Tel: 02392 - 446666 or Admin support: 02392-446670  
from Sui Generis (Betting Office and Pay Day Loan shops) to A3/A5 Classification (Restaurants and Cafes/Hot