

Department of Planning and  
Development  
Havant Borough Council  
Public Service Plaza  
Civic Centre Road  
Havant  
Hampshire  
PO9 2AX

Developer Services  
Southern Water  
Sparrowgrove House  
Sparrowgrove  
Otterbourne  
Hampshire  
SO21 2SW

Tel: 0330 303 0119

Email: [developerservices@southernwater.co.uk](mailto:developerservices@southernwater.co.uk)

Your Ref  
APP/18/01281  
Our Ref  
PLAN-026184  
Date  
07/01/2019

Dear Sirs,

**Proposal: Variation of conditions 2 (approved plans) and 3 (sewer diversion details) of Planning Permission APP/17/00511 (Proposed Gas fuelled Capacity Mechanism embedded generation plant to support the National Grid) in order to retain the existing sewer, change type of containerised generator, remove transformers and replace with a single 33kv transformer, amend size of proposed substation, reconfigure layout accordingly, replace proposed acoustic fence by a timber fence, and slightly amend fence line around the access to compound.**

**Site: Hermitage Park, Harts Farm Way, Havant, PO9 1HS.**  
**APP/18/01281**

Thank you for your letter of 18/12/2018.

Southern Water would have no objections to the above variation of condition 2 and 3. The proposed public critical sewer protection measures as shown on drawing Proposed Site Plan no. 4000\_GF\_DR\_PP\_103 Rev A are satisfactory to Southern Water.

The construction of underground services within the stand off distance of public critical sewer shall be strictly in accordance and as agreed with Southern Water. The applicant is required to contact Southern Water, Sparrowgrove House, Sparrowgrove, Otterbourne, Hampshire SO21 2SW (Tel: 0330 303 0119) or [www.southernwater.co.uk](http://www.southernwater.co.uk).

The other comments in our letter dated on 08/06/2017 remain unchanged and valid.

Yours Sincerely

A handwritten signature in black ink, appearing to read "Harta Lupton".