From: Marshall, Peter
Sent: 03 January 2018 15:47
To: Crawford, Bee
Subject: Re: APP/17/01124 - 104 Hambledon Road, Waterlooville

Further to my other email.
The Minor Planning Application Guidance from Hampshire County Council
states

GATES

If gates are to be fitted across the vehicle access then these must open inwards. To ensure that there is sufficient space for a vehicle to exit the highway to open/close the gates on entry/exit these should be set back 4.9m from the edge of the carriageway.

Peter J Marshall BSc MCIHT
Development Engineer

(My work days are Tuesday,Wednesday and Thursday)

Havant Borough Council, Public Service Plaza, Civic Centre Road, Havant , PO9 2AX
Direct Dial (023) 92446457
Email: peter.marshall@havant.gov.uk

www.havant.gov.uk
www.facebook.com/havantboroughcouncil
www.twitter.com/havantborough

Information in this message is confidential and may be privileged. It is intended solely for the person to whom it is addressed. If you are not the intended recipient, please notify the sender and delete the message from your system immediately.