

Consultee Comments for Planning Application APP/18/00148

Application Summary

Application Number: APP/18/00148

Address: Land adj 1A Sutton Road, Waterloooville, PO8 8PU

Proposal: Detached 3 bedroom dwelling with integral garage

Case Officer: Bee Crawford

Consultee Details

Name: Mrs Sally Building Control Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: bct@havant.gov.uk

On Behalf Of: Building Control

Comments

- 1) A 525mm storm water public sewer is shown on GIS running under the proposed dwelling. A consultation should be carried out with Southern Water.
- 2) There is no information on the plans to show solid waste storage on site.