

Good Morning Judith

Thank you for the attachments and identification of the exact location of the public surface water sewer within the site.

The proposals are acceptable. As the proposed extension will be located within 3 m of public sewer, we will require the foundations to be laid 150mm below the invert level of sewers.

I shall arrange a letter to be issued from our office to confirm recommendation to discharge condition 6 relating to protection of public sewers of planning application APP/17/00762.

Kind Regards
Marta Karpezo
Technical Co-ordinator
Developer Services
Southern House, Sparrowgrove, Otterbourne, Hant SO21 2SW
Tel: 01962716278
Email: marta.karpezo@southernwater.co.uk
Web: www.southernwater.co.uk

From: Judith Charles [mailto:judith@m3architecturaldesign.co.uk]
Sent: 18 October 2018 10:23
To: Karpezo, Marta <Marta.Karpezo@southernwater.co.uk>; Ballam, Rachel <Rachel.Ballam@havant.gov.uk>
Subject: Emailing 15 Waterloo Close updated13.pdf

Dear Marta

Revised plans showing extent of all drainage on site.

Thanks
Judith

Click [here](#) to report this email as spam.

This e-mail is intended solely for the person or organisation to which it is addressed. It may contain privileged and confidential information. If you are not the intended recipient, you are prohibited from copying, disclosing or distributing this e-mail or its contents (as it may be unlawful for you to do so) or taking any action in reliance on it. If you receive this e-mail by mistake, please delete it then advise the sender immediately. Without prejudice to the above prohibition on unauthorised copying and disclosure of this e-mail or its contents, it is your responsibility to ensure that any onward transmission, opening or use of this message and any attachments will not adversely affect your or the onward recipients' systems or data. Please carry out such virus and other such checks as you consider appropriate. An e-mail reply to this address may be subject to monitoring for operational reasons or lawful business practices. This e-mail is issued by Southern Water Services Limited, company number 2366670, registered in England and having its registered office at Southern House, Yeoman Road, Worthing, BN13 3NX, England. In sending this e-mail the sender cannot be deemed to have specified authority and the contents of the e-mail will have no contractual effect unless (in either case) it is otherwise agreed between Southern Water Services Limited and the recipient.

This message has been scanned for malware by Websense. www.websense.com