

From: "Coleman, Paul" <Paul.Coleman@havant.gov.uk>

Date: Wednesday, 20 June 2018 15:46

To: Ian Murray <ianmurrayijma@outlook.com>, "Chisnall, Emma" <Emma.Chisnall@havant.gov.uk>

Subject: RE: APP/18/00407- Eastview, Manor Road, Hayling Island, PO11 0QH- Update

Hi Ian/Emma,

A fire suppression system, such as a sprinkler or misting system would be suitable to overcome requirement B5 for fire authority access in this case. The design of the system would be required as part of the Building Regulation application.

As part of the planning consultation I will highlight the issue, as any amendment to the access may have an impact visually and affects the Planning Application.

Ian – It may be worth adding a brief note on the location plan showing the access that it is intended to have a sprinkler/misting system when submitting the planning application (if agreed with the applicant/client prior to submission). It may help resolve this in future as I would not need to raise the comment if I am aware it will be installed.

Thanks

Paul Coleman *BEng C.Build E MCABE*
Senior Building Control Surveyor

Havant Borough Council, Public Service Plaza, Civic Centre Road, Havant, PO9 2AX

Telephone: 02392 446577

Email: paul.coleman@havant.gov.uk

www.havant.gov.uk

www.facebook.com/havantboroughcouncil

www.twitter.com/havantborough