

From:Hill, Jessica
Sent:11 Sep 2018 11:42:54
To:Rachel.Ballam@havant.gov.uk,
Subject:23 Tower street dis charge of window details
Attachments:

Hi Rachel

The window details look fine, my one concern that I would raise is the ‘flatness’ of the external sill to the sash windows as to whether this would shed the water sufficiently? This comment is based purely on account of the very exposed location of the property right on the water front and that the driving rain is what has caused the application to be submitted.

If they wished to increase the thickness/fall of the sill ever so slightly to increase longevity of the new windows that would be permissible subject to amended plans. The agent may wish to check with the joiners doing the work.

Having said that I would not refuse the submitted application plans.
Jessica Hill
Conservation Officer

Tel: 01730 234 219 (Mon, Wed, Thurs & Fri)

East Hampshire District Council
Penns Place
Petersfield GU31 4EX
www.easthants.gov.uk
www.facebook.com/easthampshiredistrictcouncil
www.twitter.com/easthantsdc

and

Conservation Officer
Tel: 02392 446424 (Tuesday)

Havant Borough Council
Public Service Plaza
Civic Centre Road Havant PO9 2AX
www.havant.gov.uk
www.facebook.com/havantboroughcouncil
www.twitter.com/havantborough