

Plan View
Scale - 1 : 300

LEGEND								
Symbol	Label	Quantity	Catalog Number	Description	Lamp	Lumens Per Lamp	Light Loss Factor	Wattage
	A	4	DEW.LA024.AY.PGL	Denver Elite Wall, Wall Mounted at 3.5m	LED C.2000LM - 4000K	1966	0.9	24
	B	23	DEW.LA014.NR.PGL	Denver Elite Wall	LED C.1000LM - 4000K	1075	0.9	12
	C	2	DSX1.2.LA114.FW	D-Series 1 Luminaire, Wall Mounted at 8m	LED C.11000LM-4000K	11246	0.9	105
	D	5	8041AR4090EL	8041-BLIS 2 AR 90W 4000K, Wall Mounted at 6m		1213.875	0.9	90
	E	1	DSX1.2.LA114.FW	D-Series 1 Luminaire, Column Mounted at 8m	LED C.11000LM-4000K	11246	0.9	105
	F	2	DSX1.2.LA114.AY	D-Series 1 Luminaire, Column Mounted at 8m	LED C.11000LM-4000K	11264	0.9	105
	G	1	DSX1.2.LA114.SY	D-Series 1 Luminaire, Column Mounted at 8m	LED C.11000LM-4000K	11989	0.9	105

STATISTICS					
Description	Symbol	Avg	Max	Min	Min/Avg
Central Carpark		20 lux	75 lux	8 lux	0.40
Unit 1 & 2 Loading Area		51 lux	83 lux	28 lux	0.55
Unit 3 Loading Area		51 lux	83 lux	28 lux	0.55
Unit 4 Loading Area		54 lux	85 lux	26 lux	0.48
Unit 5 Carpark		23 lux	83 lux	12 lux	0.52
Unit 5 Loading Area		56 lux	80 lux	29 lux	0.52
Unit 5 Pathway		14 lux	30 lux	6 lux	0.43
Units 1 & 2 Pathway		14 lux	31 lux	6 lux	0.43
Units 3 & 4 Pathway		13 lux	29 lux	6 lux	0.46

N

2 0 2 4 6 8 10
SCALE 1:200
m

DISCLAIMER NOTES:

- THIS DOCUMENT IS COPYRIGHT OF THE ORIGINATOR AND MUST BE TREATED AS CONFIDENTIAL
- THIS DOCUMENT MUST NOT BE ALTERED, REPRODUCED OR DISTRIBUTED WITHOUT PRIOR WRITTEN CONSENT OF THE ORIGINATOR
- THIS DOCUMENT MUST NOT BE ALTERED - THE ORIGINATOR ACCEPTS NO RESPONSIBILITY FOR ANY DISCREPANCIES ARISING AS A RESULT OF THE ORIGINATORS INFORMATION BEING ALTERED BY OTHERS
- ANY DISCREPANCY MUST BE REPORTED TO THE ORIGINATOR
- DO NOT SCALE THIS DOCUMENT - USE FIGURED DIMENSIONS ONLY
- ALL DIMENSIONS MUST BE CHECKED ON SITE PRIOR TO COMMENCEMENT OF ANY RELATED WORKS
- THIS DOCUMENT MUST BE READ IN CONJUNCTION WITH ALL SUPPORTING DOCUMENTS PRODUCED BY THE ORIGINATOR AND OTHER PROJECT DISCIPLINES
- THE ORIGINATOR ACCEPTS NO RESPONSIBILITY FOR THE ACCURACY OF BACKGROUND INFORMATION PRODUCED BY THIRD PARTIES - THIS MUST BE TREATED AS INDICATIVE ONLY
- USERS OF THIS DOCUMENT ARE RESPONSIBLE FOR CHECKING WHICH REVISION IS CURRENT
- THE DOCUMENT STATUS "INFORMATION" OR "PRELIMINARY", INDICATES THAT THIS DRAWING IS FOR REFERENCE PURPOSES ONLY - THE ORIGINATOR WILL ACCEPT NO RESPONSIBILITY FOR THE COMPLETENESS OF INFORMATION UNDER THIS STATUS
- THE DOCUMENT STATUS "RECORD" OR "AS BUILT" HAS BEEN PREPARED, IN PART, BASED UPON INFORMATION FURNISHED BY OTHERS. WHILE THIS INFORMATION IS BELIEVED TO BE RELIABLE, THE ORIGINATOR ASSUMES NO RESPONSIBILITY FOR THE ACCURACY OF THIS "RECORD" OR "AS BUILT" DOCUMENT OR FOR ANY ERRORS OR OMISSIONS THAT MAY HAVE BEEN INCORPORATED INTO IT AS A RESULT OF INCORRECT INFORMATION PROVIDED TO THE ORIGINATOR. THOSE RELYING ON THE "RECORD" OR "AS BUILT" DOCUMENT ARE ADVISED TO OBTAIN INDEPENDENT VERIFICATION OF ITS ACCURACY

DRAWING NOTES:

CDM REGULATIONS 2015
SIGNIFICANT OR NON-OBVIOUS RISKS AND RISKS WHICH ARE DIFFICULT TO MANAGE ARE IDENTIFIED ON THIS DRAWING USING THE FOLLOWING SYMBOL, IDENTIFIED TO THE RIGHT WITH BRIEF ACCOMPANYING TEXT. FOR FURTHER DETAILS OF THE RISKS IDENTIFIED BY DESIGNERS, REFERENCE SHOULD BE MADE TO CDM HAZARD REGISTER.

REV	DESCRIPTION	DATE	BY	CHKD
-	FOR INFORMATION	09/03/2018	DL	LW

ORGINATOR:

RIDGE
PROPERTY & CONSTRUCTION CONSULTANTS
PARTNERSHIP HOUSE
MOORSIDE ROAD
WINCHESTER
SO23 7RX
TEL: 01962 834400
WWW.RIDGE.CO.UK

CLIENT:

SALMON

IN ASSOCIATION WITH:

PROJECT:
HARTS FARM WAY

TITLE:
EXTERNAL LIGHTING AND CALCULATION LAYOUT

DRAWN BY:	DL	SCALE: 1:200 @ A0	
CHECKED BY:	LW	DATE: 09/03/2018	

STATUS:
INFORMATION

DRAWING No:

PROJECT:	ORG	ZONE	LEVEL	TYPE	ROLE	NUMBER	REV:
5004378	RDG	XX	XX	PL	E	0100	-