

HAVANT BOROUGH COUNCIL

Town & Country Planning Act 1990

Consultation on Planning Application

MEMORANDUM

From:	Environmental Health	To:	Development Control
Our Ref:	CONS/18/00980	Your Ref:	
EH Case Officer Extn:	44 6666	Date:	31 May 2018
DC Case Officer:	David Eaves		
DC Case Officer Extn:	44 6549		
Application Number:	APP/18/00312		
Site Address:	0 Springwood Avenue, Waterloooville, PO7		
Proposed Development:	Installation of 4No. solar powered, LED street lamps, mounted on columns at the existing multi use games area (MUGA). I attach a copy of the above application that has been received under the Town and Country Planning Acts. Any views you should wish to make should be returned to me no later than 06/06/2018		

Observations / Comments:

I have reviewed the information provided in this application and can advise as follows:

As insufficient information has been provided to support this application in respect of a lighting / lux contour map or similar, I would recomend that if this applciation is to be approved that a condition be imposed with regard to the lighting proposal. I note that my colleague Jonathan Driver may have commented on this previously on the 16th May under a different address as Stakes multi use games area ? I would also concur with his conditioning of the 21:00 cut off time if this application is to receive approval

Lighting condition:

If necessary after installation of the proposed lighting scheme, to ensure that there is no light disturbance or pollution impact on nearby residential receptors, the applicant or responsible person/s shall take any or all steps required to prevent any light spillage from affecting the aforementioned properties.

Reason: To protect the occupants of nearby residential properties from light disturbance / pollution.

Mr. Mark Moss

Regulatory Officer, Environmental Health