



Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: southernwaterplanning@atkinsglobal.com

Your Ref
APP/18/00076

Our Ref
PLAN-021750

Date
21/02/2018

Dear Sirs,

Proposal: Erection of timber framed car port and shed.
Site: North Farm Cottage, Northney Lane, Hayling Island, PO11 0SE.
APP/18/00076

Thank you for your letter of 01/02/2018.

Southern Water has no objection for the above proposal.

It is the responsibility of the developer to make suitable provision for the disposal of surface water. Part H3 of the Building Regulations prioritises the means of surface water disposal in the order

- A Adequate soakaway or infiltration system
- B Water course
- C Where neither of the above is practicable sewer

Southern Water supports this stance and seeks through appropriate Planning Conditions to ensure that appropriate means of surface water disposal are proposed for each development.

Yours sincerely

A handwritten signature in black ink, appearing to read "Steve Lupton".

Developer Services

Southern Water Sparrowgrove House Otterbourne Winchester Hampshire SO21 2SW www.southernwater.co.uk

