

Consultee Comments for Planning Application APP/18/00546

Application Summary

Application Number: APP/18/00546

Address: 14 Park Lane, Bedhampton, Havant, PO9 3HH

Proposal: Single storey side extension

Case Officer: Denise Sheath

Consultee Details

Name: Mrs Sally Building Control Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: bct@havant.gov.uk

On Behalf Of: Building Control

Comments

The structure would be considered exempt from Building Regulations providing that the existing external quality door between the utility and the hallway remains in place.

It would be advisable to ensure that the external timber wall is made fire resistant internally and externally (which has been discussed with the Applicant and the Agent).