

Sarah. Thank you, the specification and position of the fence as per plan 17077-430 meets the requirements for the discharge of condition 13. Hedley.

From: Critchley Architecture and Design [mailto:info@caad.online]
Sent: 15 October 2018 13:21
To: Trembath, Hedley <Hedley.Trembath@easthants.gov.uk>
Cc: Ballam, Rachel <Rachel.Ballam@havant.gov.uk>
Subject: Re: APP/17/01071, Northney Farm Tea Room, Request to discharge condition 13

Good Afternoon,

Please find attached the fencing specification.

We trust you will find this acceptable.

Many Thanks,

Sarah Roberts
Architectural Designer



On Mon, 15 Oct 2018 at 09:09, Trembath, Hedley <Hedley.Trembath@easthants.gov.uk> wrote:



FAO Martin Critchley.

Plan 17077-430, shows the acoustic fence in position and the application to discharge describes the fence as Forest Garden Decibel contemporary profiled T&G etc fence. However the condition requires the specification of the fence i.e. its height, and noise reduction characteristics and any matters which affect its performance such as installation details. Please provide these details to progress your application. Hedley Trembath EHO.