

Rita Hegedus
Ridge and Partners LLP
Partnership House
Moorside Road
Winchester
Hampshire
SO23 7RX

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: **0330 303 0119**

Email: developerservices@southernwater.co.uk

Your Ref:

Our Ref:

SWS-HANTS-CC-003894

Date:

23/05/2018

F.A.O: Mr. Hegedus,

Site: Harts Farm Way, Havant, Hampshire, PO9 1HU.

Further to our recent correspondence concerning the capacity check for the above site. I have reviewed the proposed discharge units from your development.

Southern Water will accept the connections of 2 x toilets and 2 x wash hand basins to discharge between manhole ref. 7802 and 7701 from units 3 and 4.

Southern Water will accept the connections of 3 x toilets and 3 x wash hand basins discharging at manhole ref. 6802 from units 1, 2 and 5.

It should be noted that no further flows can be accommodated within the sewerage system and under no circumstances can surface water be discharged to the foul water system.

The nearest point where capacity is currently available to accommodate any additional flows above the agreed discharge units is located approximately 280 meters to the South of the proposed development site.

A formal S106 connection application is required to be completed and approved by Southern Water Services before any connections are made to the public sewerage system. Please find the below link

<https://developerservices.southernwater.co.uk/ConnectiontoPublicSewer/ApplicationForm>

Should you require any further information, please contact us at the above mentioned phone number or address.

Yours faithfully

A handwritten signature in blue ink, appearing to be 'Stuart Ward', written over the words 'Yours faithfully'.

Stuart Ward
Developer services

Please note: -

The information provided above does not grant approval for any designs/drawings submitted for the capacity analysis. The results quoted above are only valid for 12 months from the date of issue of this letter.