From: Mountain, Steve
Sent:09 Aug 2018 12:25:22
To: Rachel.Ballam@havant.gov.uk,
Subject:RE: APP/17/00813
Attachments:

The use of the soakaway will have to be proved by the BRE soakage test but otherwise no comments.

Steve

From: Ballam, Rachel
Sent: 09 August 2018 12:23
To: Mountain, Steve <Steve.Mountain@havant.gov.uk>
Subject: FW: APP/17/00813

Good afternoon Steve,

Do you have any objections or concerns to raise regarding the attached scheme in respect of drainage?

Apologies if you have already commented in response to the consultation response of 19/04/2018, I have not been able to locate your comments in the system.

Kind regards,

Rachel Ballam
Planning Officer: Conditions Discharge and Compliance
Planning Services
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
PO9 2AX
Direct Line: +4423 92 446 143
rachel.ballam@havant.gov.uk
www.havant.gov.uk
www.facebook.com/havantboroughcouncil
www.twitter.com/havantborough

If you are requesting information under the Freedom of Information Act, Environmental Information Regulations or Date Protection Act then please redirect your email tocustomer.services@havant.gov.uk. Any statutory timeframe for a response for requests will not commence until the request is received by the Customer Services Team.

Information in this message is confidential and may be privileged. It is intended solely for the person to whom it is addressed. If you are not the intended recipient, please notify the sender and delete the message from your system immediately.