

Consultee Comments for Planning Application APP/17/01293

Application Summary

Application Number: APP/17/01293

Address: 42 Hulbert Road, Havant, PO9 3TF

Proposal: Construction of 4No. 3 bed dwellings following demolition of existing dwelling.

(Approved 8/5/18). Request to discharge condition No/s 3, 4, 5, 6, 8, 10, 12 and 13 (16.05.18).

Case Officer: Rachel Ballam

Consultee Details

Name: Mr Stephen Mountain

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: steve.mountain@havant.gov.uk

On Behalf Of: Engineering/Drainage

Comments

Watercourse consent will be required from Hampshire CC for any work adjacent to the stream.

Flow in the stream must be maintained at all times. There have been recorded instances of flooding due to obstruction of the stream in 2000.