

Application Summary

Reference: APP/18/00546

Address: 14 Park Lane, Bedhampton, Havant, PO9 3HH

Proposal: Single storey side extension

Case Officer: Denise Sheath

Comments Details

The structure would be considered exempt from Building Regulations providing that the existing external quality door between the utility and the hallway remains in place.

Comments:

It would be advisable to ensure that the external timber wall is made fire resistant internally and externally (which has been discussed with the Applicant and the Agent).