

Consultee Comments for Planning Application APP/18/00020

Application Summary

Application Number: APP/18/00020

Address: 260-262 London Road, Waterloooville, PO7 7HG

Proposal: Erection of first floor structure on top of the existing roof to create 2No. two bed flats and alterations to the shop front to allow access to the residential units (resubmission)

Case Officer: David Eaves

Consultee Details

Name: Mrs Sally Building Control Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: bct@havant.gov.uk

On Behalf Of: Building Control

Comments

The location of the bin store will not comply with Requirement H6 of Schedule 1 of the Building Regulations. The bin store should be within 30m of the front door of the flats. In this case the bin store is over 50m from the flat entrance door