

Consultee Comments for Planning Application APP/17/01140

Application Summary

Application Number: APP/17/01140

Address: 42 Maralyn Avenue, Waterloooville, PO7 7LP

Proposal: Erection of 1No. 2 bed end of terrace dwelling.

Case Officer: Bee Crawford

Consultee Details

Name: Mrs Sally Building Control Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: bct@havant.gov.uk

On Behalf Of: Building Control

Comments

The sewer map on GIS shows a storm water public sewer at or just under 3m from the proposed building - the exact distance is unclear as unable to scale from plans in IDOX. The position of the sewer should be properly located and if within 3m of the buildings foundations a consultation should be sent to Southern Water