

From: Colin Adams

Sent: 16 August 2017 16:18

To: Harriet Pitney

Subject: RE: Planning Application APP/17/00819 at 17 Burnside, Waterloooville, PO7 7QQ

Dear Harriet

In response to your email below I would confirm that a 2 cub m soakaway at front and rear of the property should be sufficient to deal with the rain water from existing house and extension roof areas.

This is based on 20sq meters of roof being dealt with by a 1 cub meter soakaway installed in a good draining soil

The final design for the soakaway will be based on findings on site regarding soil type by the inspecting Building Control Body

Hope this is of assistance

Regards

Colin Adams BSc(Hons) MRICS FRACS

Senior Building Control Surveyor

Havant Borough Council, Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Telephone: 02392 446574 or Admin 02392 446571

Email: colin.adams@havant.gov.uk