

Consultee Comments for Planning Application APP/18/00313

Application Summary

Application Number: APP/18/00313

Address: Land to rear of 13 Middle Park Way, Havant

Proposal: Demolition of 8No. garages and erection of a 2 storey dwelling to provide 4No. of 1 bed flat.

Case Officer: Rachael McMurray

Consultee Details

Name: Mrs Sally Building Control Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: bct@havant.gov.uk

On Behalf Of: Building Control

Comments

Access to comply with Approved Document B5 Fire Authority access requirements

Flat 1 entrance door should be fire rated to protect means of escape from Flats 3 & 4. This would include Flat 2 window also

This is covered by Approved Document B Vol 2 Section 5 part 5.25

Bin storage to comply with Approved Document H6 requirement