

Consultee Comments for Planning Application APP/18/00300

Application Summary

Application Number: APP/18/00300

Address: Rear of 70 Havant Road, Hayling Island, PO11 0LH

Proposal: Erection of 1No. four bedroom two storey detached house with attached garage.

Case Officer: Daphney Haywood

Consultee Details

Name: Mrs Sally Building Control Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: bct@havant.gov.uk

On Behalf Of: Building Control, Havant Borough Council

Comments

The proposal would not currently comply with Requirement B5. Amendments to the access drive will be required or additional measures such as a sprinkler system will be needed.

Bin storage for the new dwelling will be required.

Further details for the disabled access at the front of the property will be required.