

Department of Planning and  
Development  
Havant Borough Council  
Public Service Plaza  
Civic Centre Road  
Havant  
Hampshire  
PO9 2AX

Developer Services  
Southern Water  
Sparrowgrove House  
Sparrowgrove  
Otterbourne  
Hampshire  
SO21 2SW

Tel: 0330 303 0119

Email: [southernwaterplanning@atkinsglobal.com](mailto:southernwaterplanning@atkinsglobal.com)

APP/18/00448

Our Ref

PLAN-023062

Date

04/06/2018

Dear Sirs,

**Proposal: Demolition of existing dwelling and construction of a replacement 1No. 3 bed detached dwelling, including balcony to front elevation, balcony and external staircase to rear elevation, flue to western elevation, existing garage refurbishment with render cladding.**  
**Site: Grey Havens, 9 Western Parade, Emsworth, PO10 7HS.**  
**APP/18/00448**

Thank you for your letter of 15/05/2018.

Please find attached a plan of the sewer records showing the approximate position of a public foul sewer crossing the site. The exact position of the public sewers must be determined on site by the applicant before the layout of the proposed development is finalised.

Construction within 3 meters of this public foul sewer will not be permitted. It might be possible to divert the public foul sewer, so long as this would result in no unacceptable loss of hydraulic capacity, and the work was carried out at the developer's expense to the satisfaction of Southern Water under the relevant statutory provisions.

Please note:

1. The 225mm diameter sewer requires a clearance of 3 metres either side of the sewer to protect it from construction works and allow for future access for maintenance. No development or new tree planting should be located within 3 metres either side of the external edge of the public sewer.
2. No new soakaways should be located within 5 metres of a public sewer.
3. All other existing infrastructure should be protected during the course of construction works.

Alternatively, the applicant may wish to amend the site layout, or combine a diversion with amendment of the site layout. If the applicant would prefer to advance these options, items (1) – (4) above also apply.

In order to protect drainage apparatus, Southern Water requests that if consent is granted, a condition is attached to the planning permission. For example “The developer must advise the local authority (in consultation with Southern Water) of the measures which will be undertaken to protect/ divert the public foul sewers, prior to the commencement of the development.”

Due to changes in legislation that came in to force on 1st October 2011 regarding the future ownership of sewers it is possible that a sewer now deemed to be public could be crossing the above property. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its condition, the number of properties served, and potential means of access before any further works commence on site. The applicant is advised to discuss the matter further with Southern Water, Sparrowgrove House, Sparrowgrove, Otterbourne, Hampshire SO21 2SW (Tel: 0330 303 0119) or [www.southernwater.co.uk](http://www.southernwater.co.uk).

Southern Water requires a formal application for a connection to the public foul sewer to be made by the applicant or developer. We request that should this application receive planning approval, the following informative is attached to the consent:

A formal application for connection to the public sewerage system is required in order to service this development, please contact Southern Water, Sparrowgrove House, Sparrowgrove, Otterbourne, Hampshire SO21 2SW (Tel: 0330 303 0119) or [www.southernwater.co.uk](http://www.southernwater.co.uk). Please read our New Connections Services Charging Arrangements documents which has now been published and is available to read on our website via the following link <https://beta.southernwater.co.uk/infrastructure-charges>.

The Council’s Building Control officers or technical staff should be asked to comment on the adequacy of soakaways to dispose of surface water from the proposed development.

Land uses such as general hardstanding that may be subject to oil/petrol spillages should be drained by means of oil trap gullies or petrol/oil interceptors.

The design of drainage should ensure that no land drainage or ground water is to enter public sewers network.

Yours sincerely



Developer Services