



Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: southernwaterplanning@atkinsglobal.com

Your Ref

APP/17/00848

Our Ref

PLAN-021686

Date

19/02/2018

Dear Sirs,

Proposal: Erection of two storey, 3 bedroom end of terrace dwelling with new driveway off Blendworth Crescent to serve existing property. (11.10.17). Request to Discharge condition No's. 4,5, 7 and 11 (17/01/18).

Site: 1 Blendworth Crescent, Havant, PO9 2BA.

APP/17/00848

Thank you for your letter of 29/01/2018.

Southern Water would recommend discharge of condition 11 relating to protection of public sewers. Please note that the above approval is granted only for the existing garage built over the public critical sewer to remain in its existing condition. In case of any changes to the line of the garage walls, foundations, additional load applied, the existing garage will to be required to be relocated.

The design of drainage should ensure that no land drainage or groundwater is to enter public sewers network.

Yours sincerely

A handwritten signature in black ink, appearing to read "Santa Kuper".

Developer Services