

# **Consultee Comments for Planning Application APP/17/00829**

## **Application Summary**

Application Number: APP/17/00829

Address: Land to the rear of 31 North Crescent, Hayling Island, PO11 9LR

Proposal: Erection of 1No. 1bed single storey dwelling for holiday let.

Case Officer: Daphney Haywood

## **Consultee Details**

Name: Mrs Sally Building Control Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: bct@havant.gov.uk

On Behalf Of: Building Control

## **Comments**

The timber cladding on the south-west elevation will need to be 30 minutes fire resistant.