

# **Consultee Comments for Planning Application APP/16/01077**

## **Application Summary**

Application Number: APP/16/01077

Address: Eastleigh House, Bartons Road, Havant, PO9 5NA

Proposal: Residential development to provide 9 dwellinghouses along with the continued use of Eastleigh House as Class B1(a) offices and the demolition of outbuildings to the rear of the building.(approved 21.01.17) Request to discharge condition No.s 2,5,6,7,8,9,and 14 (26.05.17).

Case Officer: Rachael McMurray

## **Consultee Details**

Name: Mr Stephen Mountain

Address: 2 Penner Road, Havant PO9 1QH

Email: [steve.mountain@havant.gov.uk](mailto:steve.mountain@havant.gov.uk)

On Behalf Of: Engineering/Drainage

## **Comments**

Surface water is shown as draining into the foul system. This may not be acceptable to Southern Water since the sewerage system in the Borough is based on separate foul / surface. At the very least I assume specific consent from SW will be required for this proposal.