

PETER J. WALKER
ISLAND DESIGN
182 SEAFRONT, HAYLING ISLAND, HANTS
PO11 9AN

TEL: 02392467571

5 June 2017

Planning Dept.,

Havant Borough Council.

PROPOSED SINGLE STORE ADDITION. REF APP/17/00578
62, SANDY POINT ROAD, HAYLING ISLAND, HANTS
FLOOD RISK ASSESSMENT.

- 1 The extension will be built in masonry materials
- 2 Floor level will be at the same level and no lower than the existing dwelling.
3. Plug and switch heights to be above flood level and wired downwards
4. The extension will not increase the number of bedrooms.
5. In the event of a flood there will be no greater pressure on the emergency services as a result of this addition.

Should you require any further information please do not hesitate to contact me.

Yours sincerely,

P J WALKER