

Consultee Comments for Planning Application APP/17/01243

Application Summary

Application Number: APP/17/01243

Address: 208 London Road, Waterlooville, PO7 7AN

Proposal: Erection of a single storey building to accommodate a nursery for a maximum number of 78 children including outside play area together with formation of car park, provision of boundary treatment and landscaping and alterations to existing pedestrian and vehicular accesses following demolition of existing house.

Case Officer: Rachael McMurray

Consultee Details

Name: Mr Stephen Mountain

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: steve.mountain@havant.gov.uk

On Behalf Of: Engineering/Drainage

Comments

I am not sure whetehr the soils will accept soakaway type disposal of surface water from such a large structure so the assumption should be to positively drain to the surface water sewer.

No other drainage comments