

Consultee Comments for Planning Application APP/17/01000

Application Summary

Application Number: APP/17/01000

Address: 59 Sandy Point Road, Hayling Island, PO11 9RR

Proposal: Erection of 1No. 5 bed detached dwelling (following demolition of existing).

Case Officer: Tina Pickup

Consultee Details

Name: Mrs Sally Building Control Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: bct@havant.gov.uk

On Behalf Of: Building Control

Comments

Windows on west elevation cannot exceed 1m² in area as these are within 1 m of the boundary.

Bin storage provisions required.