

Consultee Comments for Planning Application APP/17/01136

Application Summary

Application Number: APP/17/01136

Address: Land adj. 1 Dockenfield Close, Havant, PO9 3ST

Proposal: Construction of 1No. 2bed dwelling with associated refuse and cycle storage, parking and landscaping.

Case Officer: Daphney Haywood

Consultee Details

Name: Mrs Sally Building Control Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: bct@havant.gov.uk

On Behalf Of: Building Control

Comments

The sewer map on GIS shows a foul water public sewer within 3m of the proposed front elevation and a storm water public sewer within 3m of the proposed side elevation. A consultation should be carried out with Southern Water