



Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX



Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119
Email: developerservices@southernwater.co.uk

Your Ref
APP/16/00753
Our Ref
PLAN-015045
Date
11/08/2016

Dear Sirs,

Proposal: Erection of detached double garage to rear of dwelling to include replacement block paving to drive.
Site: 18 Delft Gardens, Waterlooville, PO8 8SP.
APP/16/00753

Thank you for your letter of 02/08/2016.

Please find attached a plan of the sewer records showing the approximate position of a public surface water sewer and foul sewer crossing the site. The exact position of the public sewers must be determined on site by the applicant before the layout of the proposed development is finalised.

From our initial assessment of the existing apparatus it appears that there is limited opportunity to divert existing surface water drainage apparatus, and therefore Southern Water objects to the proposed development. If planning permission were to be granted, Southern Water (as the statutory sewerage undertaker) would request that the Council (as the Building Control Authority) refuse Building Regulations approval on the grounds that building over the public sewer cannot be permitted.

In order to progress the proposed development on the site, the layout must be amended. In considering an amended layout:

- The 675 mm diameter surface water sewer requires a clearance of 3.5 metres either side of the sewer to protect it from construction works and allow for future access for maintenance.
- No development or new tree planting should be located within 3.5 metres either side of the centreline of the public sewer.
- The 150 mm diameter foul sewer requires a clearance of 3.5 metres either side of the sewer to protect it from construction works and allow for future access for maintenance.

- No development or new tree planting should be located within 3.5 metres either side of the centreline of the public sewer.
- No new soakaways should be located within 5m of a public sewer.
- All other existing infrastructure should be protected during the course of construction works.

Due to changes in legislation that came in to force on 1st October 2011 regarding the future ownership of sewers it is possible that a sewer now deemed to be public could be crossing the above property. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its condition, the number of properties served, and potential means of access before any further works commence on site. The applicant is advised to discuss the matter further with Southern Water, Sparrowgrove House, Sparrowgrove, Otterbourne, Hampshire SO21 2SW (Tel: 0330 303 0119) or www.southernwater.co.uk.

Southern Water requires a formal application for a connection to the public surface water sewer to be made by the applicant or developer.

We request that should this application receive planning approval, the following informative is attached to the consent:

"A formal application for connection to the public sewerage system is required in order to service this development, Please contact Southern Water, Sparrowgrove House, Sparrowgrove, Otterbourne, Hampshire SO21 2SW (Tel: 0330 303 0119) or www.southernwater.co.uk".

It is the responsibility of the developer to make suitable provision for the disposal of surface water. Part H3 of the Building Regulations prioritises the means of surface water disposal in the order

- a Adequate soakaway or infiltration system
- b Water course
- c Where neither of the above is practicable sewer

Southern Water supports this stance and seeks through appropriate Planning Conditions to ensure that appropriate means of surface water disposal are proposed for each development.

The proposed development would lie within a Source Protection Zone around one of Southern Water's public water supply sources as defined under the Environment Agency's Groundwater Protection Policy. Southern Water will rely on your consultations with the Environment Agency to ensure the protection of the public water supply source.

Yours sincerely

A handwritten signature in blue ink, appearing to read "Smith".

Developer Services

SOUTHERN WATER



The positions of pipes shown on this plan are believed to be correct, but Southern Water Services Ltd accept no responsibility in the event of inaccuracy. The actual positions should be determined on site.

Based upon Ordnance Survey Digital Data with the permission of the controller of
H.M.S.O. Crown Copyright Reserved Licence No. WH 298530

O.S. REF: SU6710NE

Scale: 1:1250

Screen Print

WARNING: BAC pipes are constructed of Bonded Asbestos Cement
WARNING: Unknown (UNK) materials may include Bonded Asbestos Cement



Printed By: jayavar Date: 11-8-2016

Southern Water MapGuide-Browser.

Requested By: