



Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: developerservices@southernwater.co.uk

Your Ref
APP/16/00379

Our Ref
PLAN-017957

Date
26/04/2017

Dear Sirs,

Proposal: Erection of 11No. 3 bedroom houses, 2No. 2 bedroom houses and 5No. 2 bedroom flats (approved 20.2.17). Request to Discharge Condition Nos 3, 4, 5, 8, 9, 10, 11, 13, 14, 18, 19, 21 and 22 (recd 27.3.17)
Site: Land South of, Ranelagh Road, Havant, PO9 1NR.
APP/16/00379

Thank you for your letter of 06/04/2017.

Southern Water would not recommend discharge of condition 3. Submitted drainage layout (Drawing no. 14-2260-500 Rev C7) shows proposed soakaway over public sewer.

Please note that no soakaways, swales, ponds, watercourses or any other surface water retaining or conveying features should be located within 5 metres of public or adoptable sewers.

Yours sincerely

A handwritten signature in black ink, appearing to read "Santa Lopez".

Developer Services