

Consultee Comments for Planning Application APP/17/00529

Application Summary

Application Number: APP/17/00529

Address: 380 Sea Front, Hayling Island, PO11 0BD

Proposal: Erection of 13 residential apartments including parking and landscaping following demolition of existing building.

Case Officer: Tina Pickup

Consultee Details

Name: Mrs Sally Building Control Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: bct@havant.gov.uk

On Behalf Of: Building Control

Comments

Access to the new building to comply with Requirement B5 in regards to the surface, provision of turning circle, and the trees along access drive would have to be maintained to a sufficient height not to affect Fire Authority vehicles.

A public surface water sewer is located on the site, Southern Water to be consulted.