



Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX



Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119
Email: developerservices@southernwater.co.uk

Your Ref
APP/16/00735
Our Ref
PLAN-014967
Date
17/08/2016

Dear Sirs,

Proposal: Use of land for open storage comprising vehicles and scaffolding (use class B8) and perimeter landscaping works.
Site: Land Adjacent to, 132 Havant Road, Hayling Island, PO11 0LJ.
APP/16/00735

Thank you for your letter of 28/07/2016.

Southern Water would have no objections to the above proposals.

Please find attached a plan of the sewer records showing the approximate position of a public foul sewers within the site. No storage or tree planting is allowed within 3 metres of the 300mm foul sewer and 3.5 metres of the 525mm foul sewer.

Reference should be made to Southern Water publication "A Guide to Tree Planting near water Mains and Sewers" with regards to any Landscaping proposals.

Yours sincerely


Developer Services

SOUTHERN WATER

HAVANT BOROUGH COUNCIL

18 AUG 2016

RECEIVED



The positions of pipes shown on this plan are believed to be correct, but Southern Water Services Ltd accept no responsibility in the event of inaccuracy. The actual positions should be determined on site.

Based upon Ordnance Survey Digital Data with the permission of the controller of HMSO. Crown Copyright Reserved Licence No. WU1298530

O.S. REF: SU7102NE

Scale: 1:1250

Screen Print

WARNING: BAC pipes are constructed of Bonded Asbestos Cement
WARNING: Unknown (UNK) materials may include Bonded Asbestos Cement

Southern Water

Printed By: NadigaJ

Date: 8-8-2016

Southern Water MapGuide Browser

Requested By: