

Consultee Comments for Planning Application APP/17/00863

Application Summary

Application Number: APP/17/00863

Address: Southleigh Park House, Eastleigh Road, Havant, PO9 2PE

Proposal: Hybrid Application - Full Application for change of use, alterations to and extension of existing buildings to 20 Residential units, (13 dwellings in the main house and 7 in other Listed Buildings) with associated landscaping parking and amenity space. |cr|Outline Application (All Matters Reserved except means of access) for the demolition of 1983 office building and associated brick and glass corridor link and development of up to 70 residential units, associated landscaping, parking and infrastructure works.

Case Officer: Rachael McMurray

Consultee Details

Name: Mrs Sally Building Control Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: bct@havant.gov.uk

On Behalf Of: Building Control

Comments

Consultation with Southern water as Public Sewer is within part of the site

Solid waste storage provisions as required under AD H have not been shown

Further information will be required when a Building Regulation application is submitted to show compliance with ALL AD's