

Subject: APP/17/00903 - 9 Park Crescent, Emsworth

Dear Harriet,

Arboricultural Officer comments: A beech and Privet hedge form the front boundary and a Holme Oak protected by a Tree Preservation Order stands adjacent to the road frontage. There are no above ground tree constraints as the proposed gates will not impact on the crown of the tree, but there are below ground constraints. A method statement is required to be submitted with particular reference to ground levels and how any levelling will be undertaken to ensure the roots of the Holme Oak are not damaged.

Thanks

Maria Stewart – Arboricultural Officer
East Hampshire District Council, Penns Place, Petersfield, GU31 4EX
Tel: 01730 234214
Email: maria.stewart@easthants.gov.uk

www.easthants.gov.uk
facebook.com/EastHampshireDistrictCouncil
twitter.com/EastHantsDC