

Consultee Comments for Planning Application APP/17/00358

Application Summary

Application Number: APP/17/00358

Address: Land west of Horndean Road and south of Southleigh Road

Proposal: Application for approval of matters reserved under outline permission APP/14/00547 (layout, scale, appearance and landscape) for development comprising 125 residential dwellings, associated amenity spaces, access, garages, parking, internal roads, pathways, sustainable urban drainage and associated landscaping in addition to the provision of a water retention area.

Case Officer: Lewis Oliver

Consultee Details

Name: Mrs Sally Building Control Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: bct@havant.gov.uk

On Behalf Of: Building Control, Havant Borough Council

Comments

Comments previously raised 27 April 17 still stand:

Southern Water Services to be consulted re sewer

Fire Authority access within site needs to comply with AD B Part 5