

Consultee Comments for Planning Application APP/17/00412

Application Summary

Application Number: APP/17/00412

Address: St Peters Square, Emsworth, PO10 7AF

Proposal: 6No. signs.

Case Officer: Tina Pickup

Consultee Details

Name: Consultee Comments - Highway Authority (HBC Agency)

Address: 2 Penner Road, Havant PO9 1QH

Email: peter.marshall@havant.gov.uk

On Behalf Of: Development Engineer - Highways

Comments

The attachment of any sign to a lamppost requires the permission of the Highway Authority <http://www3.hants.gov.uk/street-lighting-policy.pdf> is a link to the HCC Street Lighting Policy Document (4th edition).

The relevant paragraph reads

OTHER FIXTURES TO STREET LIGHTING COLUMNS (PERMANENT OR TEMPORARY)

In general, street lighting columns, whether used for permanent or temporary fixtures, should comply with the guidelines indicated in DTLR Memorandum BD 94 This means that the erection of sign plates of greater than 0.3 square metres in area is not permitted. Columns must not be used as the second leg of a sign requiring a second post, as experience has shown that this has caused significant problems with existing columns.

Street lighting columns shall not be used as supports for advertising signs of any kind, except where recognised organisations (ie Automobile Association or Royal Automobile Club) have been granted permission by the Highway Authority, and when fixed such signs should not obscure the unit maintenance number.

This approval must obtained in order for the application can be dealt with