



Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX



Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: developerservices@southernwater.co.uk

Your Ref
APP/16/00812
Our Ref
PLAN-015183
Date
24/08/2016

Dear Sirs,

Proposal: Reserved matters application for demolition of existing building and structures and redevelopment of the site with the erection of 3No. units relating to layout, appearance and landscaping . Discharge of conditions Nos 3,4,5,6,7,10,14,15,16 of Outline Application APP/15/00284. (Site Option 1)
Site: Site of Former Warehouse - Velocity 1 Stanbridge Road, Havant, PO9 2NP.
APP/16/00812

Thank you for your letter of 12/08/2016.

Southern Water has no comments to make in respect of the reserved matters submitted by the applicant.

Southern Water would have no objections to discharge condition 7 relating to foul and part of surface water drainage (rate of discharge to surface water sewer should be no greater than existing contributing flows).

Approval for the connection should be obtained under a Section 106 (connection to the public sewer) application.

The Council's Building Control officers/technical staff and the Environment Agency should be consulted regarding the discharge condition for surface water disposal.

Yours sincerely

Southern Water Sparrowgrove House Otterbourne Winchester Hampshire SO21 2SW www.southernwater.co.uk

Southern Water Services Ltd Registered Office: Southern House Yeoman Road Worthing BN13 3NX Registered in England No.2366670

SOUTHERN WATER

HAVANT BOROUGH
COUNCIL

- 5 SEP 2016

RECEIVED



The positions of pipes shown on this plan are believed to be correct, but Southern Water Services Ltd accept no responsibility in the event of inaccuracy. The actual positions should be determined on site.

Based upon Ordnance Survey Digital Data with the permission of the controller of H.M.S.O. Crown Copyright Reserved Licence No. WU 298530

O.S. REF: SU7207SE

Scale: 1:2500

Screen Print

WARNING: BAC pipes are constructed of Bonded Asbestos Cement
WARNING: Unknown (UNK) materials may include Bonded Asbestos Cement

 Southern
Water

Printed By: banuh

Date: 24-8-2016

Southern Water MapGuide Browser

Requested By:

