

HAVANT BOROUGH COUNCIL

Town & Country Planning Act 1990

Consultation on Planning Application

MEMORANDUM

From:	Environmental Health	To:	Development Control
Our Ref:	CONS/17/00997	Your Ref:	APP/17/00320
EH Case Officer Extn:	44 6677	Date:	28 April 2017
DC Case Officer:	Daphney Haywood		
DC Case Officer Extn:	44 6513		
Application Number:	APP/17/00320		
Site Address:	70 Havant Road, Hayling Island, PO110LH		
Proposed Development:	Erection of 3No. 4 bed detached houses with associated garages. (Revised application).		

Observations / Comments:

I have reviewed the re-submitted / revised application, and note that there are no material changes with respect to Environmental Issues. Comments as for original application - briefly summarised below:

Drainage / Flooding / Pollution

Local Policy CS15 requires that developed land must not result in a net increase in surface water run off. To achieve this, surface water storage /attenuation and controlled release may be necessary. Due to the sensitivity of the receiving environment, it may be both necessary & appropriate to seek to prior approval of a detailed scheme of surface drainage, subject to the advice of the LLFA as the appropriate authority to advise on flood risk.

Air Quality

For the reasons outlined previously, I have no adverse comments as regards air quality.

Contamination Potential

There are potential sources of contamination associated with the site. The proposed use is contamination sensitive, comprising family homes with private garden areas. The degree of sensitivity would apply irrespective of development density. No objection to the development on ground of contamination potential subject to the following conditions:

Contamination (Standard) [1]

Prior to the commencement of any specific phase of development approved by this planning permission (or such other date or stage in development as may be agreed in writing with the Local Planning Authority), an assessment of the nature and extent of contamination at the site, whether originating from within or outside the curtilage, shall be submitted to and approved in writing by the Local Planning Authority. The assessment shall be undertaken by competent persons, and the findings presented as a written report.

The assessment may comprise separate reports as appropriate, but unless specifically excluded in writing by the Local Planning Authority, shall include;

- 1) A site walk-over survey &/or sufficient desk-based research to identify;*
 - All relevant previous uses of the site*
 - Potentially significant contaminants associated with those uses*
 - Uncertainties relating to previous use or associated potential contaminants*
 - A conceptual site model identifying all relevant sources, exposure pathways and receptors, and;*
 - A summary of potentially unacceptable risks arising from contamination at the site.*
- 2) Site investigation based on (1), to provide sufficient data and information to adequately identify & characterise any physical contamination on or affecting the site, and to inform an appropriate assessment of the risks to all receptors that may be affected, including those off site.*
- 3) The results of an appropriate risk assessment based upon (1) & (2), and where unacceptable risks are identified, a Remediation Strategy that includes;*
 - appropriately considered remedial objectives,*
 - an appraisal of remedial &/or risk mitigation options, having due regard to sustainability, and;*
 - clearly defined proposals for mitigation of the identified risks.*
- 4) A verification plan providing details of the data that will be collected in order to demonstrate that the works set out in the Remediation Strategy (3) are complete, identifying any requirements for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action.*

All elements shall be adhered to unless agreed in writing by the Local Planning Authority

Reason: *Having due regard to policies DM10 of the Havant Borough Adopted Core Strategy [2011] and DM17 of the Havant Borough Local Plan (Allocations) [2014], Contamination may be present at the site as a result of previous land use (&/or activity) that could pose a risk to future occupants.*

Verification (Standard) [2]

*Prior to the occupation of any relevant part of the permitted development, any verification report required in accordance with **condition [X]** shall be submitted to and approved in writing by the Local Planning Authority.*

The report shall include results of sampling and monitoring carried out in accordance with the approved verification plan, and must demonstrate that site remediation criteria have been met. Where longer-term monitoring of pollutant linkages is identified as being necessary, the report shall clearly set out plans for monitoring, provision for maintenance, relevant triggers and contingency actions (a "long-term monitoring and maintenance plan").

The long-term monitoring and maintenance plan shall be implemented as approved.

Reason: *Having due regard to policies DM10 of the Havant Borough Adopted Core Strategy [2011] and DM17 of the Havant Borough Local Plan (Allocations) [2014], Contamination may be present at the site as a result of previous land use (&/or activity) that could pose a risk to future occupants.*

Mr. Jonathan Driver
Environmental Control Officer