



Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: developerservices@southernwater.co.uk

Your Ref

APP/16/00347

Our Ref

PLAN-017003

Date

08/02/2017

Dear Sirs,

Proposal: Erection of 26 residential units with associated works, access, parking and landscaping (approved 13.01.17). Request to Discharge Condition No.s 2, 4, 5 ,6 and 19 (18.01.17).

Site: Purbrook School Former Playing Fields, Stakes Road, Waterloo, PO7 5PW.
APP/16/00347

Thank you for your letter of 19/01/2017.

Southern Water would not recommend discharge of condition 5 relating to foul and surface water sewer. The proposed foul and surface water drainage does not comply with Sewers for Adoption standards and Southern Water requirements.

No new soakaways, swales, ponds, watercourses or any other surface water retaining or conveying features (also cellular storage) should be located within 5 metres of a public and adoptable sewers.

Southern Water would have no comments to make with regards to other conditions being subject of consultation.

Yours sincerely

A handwritten signature in black ink, appearing to read "Harte Kuper".