


Good Afternoon Simon

The proposed soakaway is exactly OVER public 600mm critical syphon sewer. Please see below screenshots.



Kind Regards

Marta Karpezo
Technical Co-ordinator
Developer Services

Southern House, Sparrowgrove, Otterbourne, Hant SO21 2SW
Tel: 01962716278

Email: marta.karpezo@southernwater.co.uk

Web: www.southernwater.co.uk

From: Simon Kennedy
Sent: 11 May 2017 13:51
To: Karpezo, Marta
Subject: RE: Planning Application APP/16/00379 Land South of, Ranelagh Road, Havant

Hi Marta.

Can you confirm that your comment only relates to the existing mains sewer on the site and the location of a single soakaway in the south-western corner of the site being only 3.5m away from the afore mentioned existing sewer?

Many thanks

Simon Kennedy

Planning Officer (Conditions Discharge & Compliance)

Planning Services

Havant Borough Council, Public Service Plaza, Civic Centre Road, Havant PO9 2AX

DD: 02392 446138

Email: simon.kennedy@havant.gov.uk