


NOTES

1. This has been provided in conjunction with the drawings provided to us by Richard McManus of McManus Design Ltd.
2. This drawing is a proposal only and should not be used as an installation drawing.
3. All products specified must be installed to the manufacturers guidelines.
4. Do not scale from this drawing.
5. Pipework has not been sized as of yet.
6. All inspection chamber and manhole cover levels have been assumed based on the new proposed levels.
7. Driveways have been advised as permeable paving. This is assumed to just soakaway and not need collected via a perforated collection pipe.
8. Road gullies have been advised in the locations assumed to pick up the surface water run off from the access road only.
9. Some of the tree locations may need to be removed or moved to allow for the soakaway locations.
10. Patio areas are assumed to be non-permeable, and therefore the surface water run off from these will be collected via the roddable rainwater gullies and soaked away via the plot soakaway's.

FOUL WATER PUMP INFORMATION

Reference: PU1230T'S
Material: Sewage
No. of Pumps: 2
Pump Type: 1510M
Inlet: 100mm
Supply Voltage: 1 Phase 230V
Method of Starting: DOL
Level Controls: Floats
Control Sequence: Duty/Standby
Length of Cable: 10 metres
GRP Chamber Diameter: 1250mm
Depth of Chamber: 3000mm
Inlet Invert: 2000mm
Inlet Connector: 200, 110mm @ 90&180°
1. Pump Outlet: 50mm Compression Fitting
2. Hose End: 50mm Compression Fitting
3. Hose Length: 800X1000 5 tonne SWL
Controls: Dial Controls Panel, Visual & Audible Alarms, 10m Cable



JDP TECHNICAL SUPPORT
Townfoot, Longtown, Carlisle, Cumbria CA6 5LY
Telephone: 01223 791503
Email: technical.support@jdpipes.co.uk
© JDP Pipes Ltd. All rights reserved

DRAWING TITLE:

Proposed Drainage Layout

DRAWING NO:	REV:
JDP-1612-69-001	-

CLIENT:

Style Front London Ltd

PROJECT:

112 London Road, Cowplain

SCALE:	DRAWN:	CHECKED:	DATE:
1:75 @ A1	G.A	T.Ho	09/01/2017

