



Department of Planning and  
Development  
Havant Borough Council  
Public Service Plaza  
Civic Centre Road  
Havant  
Hampshire  
PO9 2AX

Developer Services  
Southern Water  
Sparrowgrove House  
Sparrowgrove  
Otterbourne  
Hampshire  
SO21 2SW

Tel: 0330 303 0119  
Email: [developerservices@southernwater.co.uk](mailto:developerservices@southernwater.co.uk)

Your Ref  
APP/16/00379  
Our Ref  
PLAN-013723  
Date  
02/05/2016

Dear Sirs,

**Proposal: Erection of 9No. 2 bedroom dwellings and 9No. 3 bedroom dwellings.**  
**Site: Land South of, Ranelagh Road, Havant, PO9 1NR.**  
**APP/16/00379**

Thank you for your letter of 21/04/2016.

Submitted drainage layout (Drawing no. 14-2260-520A P1) shows proposed soakaway over public sewer.

Please note that no soakaways, swales, ponds, watercourses or any other surface water retaining or conveying features should be located within 5 metres of a public sewers.

Yours sincerely

  
Developer Services

12 MAY 2016

# SOUTHERN WATER

RECEIVED



The positions of pipes shown on this plan are believed to be correct, but Southern Water Services Ltd accept no responsibility in the event of inaccuracy. The actual position should be determined on site.

Based upon Ordnance Survey Digital Data with the permission of the controller of H.M.S.O. Crown Copyright Reserved Licence No. WU 298530

O.S. REF: SU7006SE

Scale: 1:2500

Screen Print

**WARNING:** BAC pipes are constructed of Bonded Asbestos Cement

**WARNING:** Unknown (UNK) materials may include Bonded Asbestos Cement



Printed By: banuh

Date: 29-4-2016

Southern Water MapGuide Browser

Requested By: