



Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: developerservices@southernwater.co.uk

Your Ref
APP/16/00347

Our Ref
PLAN-013736

Date
27/04/2016

Dear Sir

**Proposal: Erection of 26 residential units with associated works, access,
parking and landscaping.**
Site: Purbrook School Former Playing Fields, Stakes Road,
Waterlooville, PO75PW.
APP/16/00347

Thank you for your letter of 22/04/2016.

Our initial investigations indicate that Southern Water can provide foul and surface water sewage disposal to service the proposed development. Southern Water requires a formal application for a connection to the public sewer to be made by the applicant or developer.

We request that should this application receive planning approval, the following informative is attached to the consent:

"A formal application for connection to the public sewerage system is required in order to service this development, Please contact Southern Water, Sparrowgrove House, Sparrowgrove, Otterbourne, Hampshire SO21 2SW (Tel: 0330 303 0119) or www.southernwater.co.uk".

It is the responsibility of the developer to make suitable provision for the disposal of surface water. Part H3 of the Building Regulations prioritises the means of surface water disposal in the order

- A Adequate soakaway or infiltration system
- B Water course
- C Where neither of the above is practicable sewer

HAVANT BOROUGH
COUNCIL
11 MAY 2016
*
*RECEIVED

11 MAY 2016

RECEIVED



WARNING: BAC pipes are constructed of Bonded Asbestos Cement
WARNING: Unknown (UNK) materials may include Bonded Asbestos Cement



Requested By:

