



Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: developerservices@southernwater.co.uk

Your Ref
APP/15/01220
Our Ref
PLAN-012618
Date
08/02/2016

Dear Sir

Proposal: Change of use of land from parking bays to area for hand car wash and valeting service, incorporating installation of a cabin, a canopied area for dry washing and an open area for wet washing.
Site: Asda Stores, Hambledon Road, Waterlooville, PO7 7XR.
APP/15/01220

Thank you for your letter of 18/01/2016.

Please find attached a plan of the sewer records showing the approximate position of a public sewer in the vicinity of the site. The exact position of the public sewers must be determined on site by the applicant before the layout of the proposed development is finalised. Please note:

No development or new tree planting should be located within 3 metres either side of the centreline of the 300mm, 225mm & 150mm public surface water sewers.

No development or new tree planting should be located within 3 metres either side of the centreline of the 225 & 150 mm public foul sewers.

No development or new tree planting should be located within 3.5 metres either side of the centreline of the 600mm public surface water sewers.

All existing infrastructure should be protected during the course of construction works.

No new soakaways should be located within 5 metres of a public sewers.

Due to changes in legislation that came in to force on 1st October 2011 regarding the future ownership of sewers it is possible that a sewer now deemed to be public could be crossing the above property. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its condition, the number of properties served, and potential means of access before any further works commence on site. The applicant is advised to discuss the matter

further with Southern Water, Sparrowgrove House, Sparrowgrove, Otterbourne, Hampshire SO21 2SW (Tel: 0330 303 0119) or www.southernwater.co.uk".

The Environment Agency should be consulted regarding the use of a private drainage.

If any foul connections are proposed to public sewerage system. Areas used for vehicle washing should only be connected to the foul sewer after consultation with Southern Water. The applicant is advised to discuss the matter further with Southern Water's Trade Effluent Inspectors. Please see <https://www.southernwater.co.uk/BusinessCustomers/wasteServices/tradeEffluent/> for further information.

Land uses such as general hardstanding that may be subject to oil/petrol spillages should be drained by means of oil trap gullies or petrol/oil interceptors.

The proposed development would lie within a Source Protection Zone around one of Southern Water's public water supply sources as defined under the Environment Agency's Groundwater Protection Policy. Southern Water will rely on your consultations with the Environment Agency to ensure the protection of the public water supply source.

We request that should this application receive planning approval, the following condition is attached to the consent: "Construction of the development shall not commence until details of the proposed means of foul and surface water sewerage disposal have been submitted to, and approved in writing by, the Local Planning Authority in consultation with Southern Water."

Yours sincerely


Developer Services

RECEIVED

