Southern Water

HAVANT BOROUGH COUNCIL
11 MAY 2016
RECEIVED

Department of Planning and Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119
Email: developerservices@southernwater.co.uk

Your Ref
APP/11/01082
Our Ref
PLAN-013698
Date
09/05/2016

Dear Sirs,

Proposal: Discharge of condition 11 of planning permission APP/11/01082. (Outline application for residential development for 34No. dwellings with access from Barncroft Way, and 4No. dwellings with access from Park Lane, and with all other matters reserved (approved 26/06/2013).
Site: Former site of Barncroft Infant School, Barncroft Way, Havant, PO9 3AG. APP/11/01082

Thank you for your letter of 19/04/2016.

Southern Water would have no objections to discharge condition 11 relating to drainage details.

The connection of rising main from the adjacent development, discharged flow rates and mode of connection shall be subject to separate assessment and approval from Southern Water.

The information provided by the applicant indicates the proposals to offer the drainage for adoption before the construction, while the connection to the public foul and surface water network was already carried out. Any proposals to offer the drainage for adoption should comply with Sewers for Adoption standards.

Yours sincerely

Developer Services