

Karen Wooden

From: Sally Smith DC
Sent: 23 April 2013 15:04
To: bst shared
Subject: Taylor Wimpey

Please import into APP/12/00201 as additional landscape comment

Sally Smith
Senior Planner
Development Control
Havant Borough Council
Public Service Plaza
Havant
PO9 2AX

Direct line: 0239 2446522
Fax: 0239 2446588
sally.smith.dc@havant.gov.uk
www.havant.gov.uk

From: Julie Boschi
Sent: 13 March 2012 16:55
To: Sally Smith DC
Subject: RE: Planning APP/12/00149 - removal of bund condition TW

Sally

I am happy to see the bund removed from this scheme as I think that the proposed vegetation screen will establish much quicker without the drought stress it would impose on the trees and shrubs planted on it. However, the width of the proposed dry shrub mix plant bed should be increased to give a total native shrub buffer of 5 metres minimum width along the Brambles Business Park boundary. I also recommend increasing the proportion of Ilex aquifolium - the only evergreen species in the mix - to 20% to give a better screen in winter.

Julie

Julie Boschi
Senior Landscape Architect
Havant Borough Council
Southmoor Offices
2 Penner Road
Havant PO9 1QH

Tel 02392 446536 Fax 02392 498031

julie.boschi@havant.gov.uk

From: Sally Smith DC
Sent: 12 March 2012 13:16
To: Les Glass; Julie Boschi
Subject: Planning APP/12/00149 - removal of bund condition TW

Hi,

I know you have both expressed views on the proposal to move the bund in other communications.

However, we now have the formal application to remove the condition and I know consultations were issued on 8th. Please could you reprovide your views under this application reference so I can place them on file.

You may be interested that the application includes a covering letter as well as the WSP acoustic submission.

If this could possibly be done in the next couple of days that would be really good as it all feeds into how the TW 3 and 4 phases shape up.

Many thanks

Sally

Sally Smith
Senior Planner
Development Control
Havant Borough Council
Public Service Plaza
Havant
PO9 2AX

Direct line: 0239 2446522
Fax: 0239 2446588
sally.smith.dc@havant.gov.uk
www.havant.gov.uk