

Consultee Comments for Planning Application APP/24/00275

Application Summary

Application Number: APP/24/00275

Address: 31 Snowberry Crescent, Havant, PO9 2FE

Proposal: Installation of air source heat pump to the rear of the property. Planning permission sought, as the noise level of the heat pump is 45db.

Case Officer: Robert Riley

Consultee Details

Name: Consultee Environmental Health (Environment Team)

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: Not Available

On Behalf Of: Environmental Health Manager, Community Group

Comments

Thank you for consulting the Environmental Protection Team on this application. Please note these comments relate to noise only. We recommend refusal of the development in order to avoid the potential significant adverse effects of the impact of noise upon the health and quality of life of nearby dwellers. Any future application will need to be supported with a British Standard 4142:2014+A1:2019 noise report in order to assess the potential noise impact of the plant on nearby noise sensitive receptors. However, a noise report may be avoided by repositioning the plant so that it is further away from receptors, and a MCS recalculation may be beneficial by indicating if repositioning the plant would be helpful.

Regards

Helen Le-Vallee

Environmental Health Officer

Havant Borough Council