

Consultee Comments for Planning Application APP/24/00180

Application Summary

Application Number: APP/24/00180

Address: 14 Glenleigh Park, Havant, PO9 2PH

Proposal: Installation of air source heat pump. Planning required due to noise level being 45db.

Case Officer: Josephine Lacey

Consultee Details

Name: Consultee Environmental Health (Environment Team)

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: Not Available

On Behalf Of: Environmental Health Manager, Community Group

Comments

Thank you for consulting the Environmental Protection Team on this application. The noise calculations provided confirms that the ASHP would not come under permitted development. As such, as part of any future full application we require a British Standard 4142:2014+A1:2019 be submitted in order to assess the potential impacts of noise from the plant, clearly detailing any mitigation measures that are required with clear calculations showing the expected noise reduction. Without this assessment we recommend that this application be refused in order to avoid significant adverse effects of noise on health.

Regards

Helen Le-Vallee

Environmental Health Officer

Environmental Protection Team

Havant Borough Council