



---

**RE: APP/24/00818**

---

**From** tom@atpad.co.uk <tom@atpad.co.uk>

**Date** Wed 27-Nov-24 1:10 PM

**To** Riley, Robert <Robert.Riley@havant.gov.uk>

**CAUTION:** This email came from outside of the council - only open links and attachments that you're expecting.

Hi Rob

Thanks for sending over building controls comments re the unprotected areas.

Boundary to neighbouring property is 910mm and window to side elevation is 0.6m<sup>2</sup>.

External timber frame wall with cladding will have a 9mm Magply board fixed over the 12mm ply sheathing (then breather membrane, counter battens, battens, composite cladding) for external treatment and lined on internal side of studs with 15mm Gyproc fireline board with a 3mm plaster skim finish.

Kind Regards,

Tom Peters  
ATP Architectural Design  
07590 762966  
[www.atpad.co.uk](http://www.atpad.co.uk)



This email and its attachments are intended for the person or entity to whom the email is addressed and may contain material which is confidential. You should not copy or disclose its contents to any other person. If you have received this email in error please notify ATP Architectural Design immediately.

ATP Architectural Design is the trading name of ATP Design Ltd (12131949) a private limited company in England and Wales, whose registered office is at 81 High Street, Cosham, Hampshire PO6 3BL.

---

**From:** Riley, Robert <Robert.Riley@havant.gov.uk>

**Sent:** 26 November 2024 15:32

**To:** tom@atpad.co.uk

**Subject:** APP/24/00818